

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 110700-E207782
ISSUE DATE: July 11, 2000

Page 1 of 1

Issued to: Tridium Inc.
3951 Westree PKY, suite 350
Richmond, VA 23233

Report Reference: E207782, March 3, 2000


This is to Certify that representative samples of: Energy Management Equipment: Models JACE-NP followed by 1, 1I, 2, or 2I.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: United States Standards- Listed UL 916
Canadian Standards- Listed C22.2 No 205- M1983


Additional Information: Electrical Ratings:
JACE - NP - 1L & JACE - NP - 21: 240 V ac, 50/60 Hz ,0.9 A
JACE - NP - 1 & JACE - NP 2: 120 V ac, 50/60 Hz ,1.7 A

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers;  as the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE LISTING MARK ON THE PRODUCT

Engineer: 
Louis Crawford
Underwriters Laboratories Inc.

Review Engineer: 
Eddie White
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service